

# **Requirements for Electrical Installations**

**IET Wiring Regulations  
Eighteenth Edition**

## Publication Information

Published by the Institution of Engineering and Technology, London, United Kingdom in agreement with BSI.

The Institution of Engineering and Technology is registered as a Charity in England & Wales (no. 211014) and Scotland (no. SC038698).



The Institution of Engineering and Technology is the institution formed in 2006 by the joining together of the IEE (the Institution of Electrical Engineers) and the IIE (the Institution of Incorporated Engineers).



British Standards Institution is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

© 2008, 2011, 2013, 2015, 2018, 2020, 2022 the Institution of Engineering and Technology and BSI.

This British Standard (BS 7671:2018+A2:2022) was published under the joint authority of the IET and of the Standards Policy and Strategy Committee on 28 March 2022.

This publication is copyright under the Berne Convention and the Universal Copyright Convention. All rights reserved. Apart from any fair dealing for the purposes of research or private study, or criticism or review, as permitted under the Copyright, Designs and Patents Act 1988 this publication may be reproduced, stored or transmitted, in any form or by any means, only with the prior permission in writing of the publishers, or in the case of reprographic reproduction in accordance with the terms of licences issued by the Copyright Licensing Agency. Enquiries concerning reproduction outside those terms should be sent to the publishers at The Institution of Engineering and Technology, Futures Place, Kings Way, Stevenage, SG1 2UA United Kingdom.

While the publisher and contributors believe that the information and guidance given in this work is correct, all parties must rely upon their own skill and judgement when making use of it. The publisher and contributors do not assume any liability to anyone for any loss or damage caused by any error or omission in the work, whether such error or omission is the result of negligence or any other cause. Any and all such liability is disclaimed.

The UK participation in its preparation was entrusted to Joint Technical Committee JPEL/64 Electrical Installations. A list of organizations represented on this committee can be obtained on request to its Committee Manager.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application. Compliance with a British Standard cannot confer immunity from legal obligations.

It is the constant aim of the IET and BSI to improve the quality of our products and services. We should be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Committee Manager, M. Coles {mcoles@theiet.org}, The IET, Futures Place, Kings Way, Stevenage, SG1 2UA, United Kingdom.

## **BS 7671:2018+A2:2022 - Corrigendum (May 2023)**

Changes and additions shown in **red**

# BS 7671:2018+A2:2022 - Corrigendum (May 2023)

## CONTENTS

INTRODUCTION	5
422 PRECAUTIONS WHERE PARTICULAR RISKS OF FIRE EXIST	6
443 PROTECTION AGAINST TRANSIENT OVERVOLTAGES OF ATMOSPHERIC ORIGIN OR DUE TO SWITCHING	7
534 DEVICES FOR PROTECTION AGAINST OVERVOLTAGE	9
701 LOCATIONS CONTAINING A BATH OR SHOWER	10
710 MEDICAL LOCATIONS	11

## Introduction to Corrigendum (May 2023)

This Corrigendum contains corrections to BS 7671:2018+A2:2022 and is intended for immediate implementation. For clarification, where appropriate, deleted text has been ruled through and changes and additions shown in red. Sufficient existing text has been included to enable users to identify the nature, extent and application of the change to each provision.

Regulation 422.2 has been amended to clarify the scope of the provision.

Indent (ii) of Regulation 443.4.1 has been deleted. The term *safety service*, formerly included in Regulation 443.4.1 (ii), encompassed a wide range of systems. The provision, therefore, had unintended consequences for improvements to fire safety systems within installations.

Table 443.2 and the Note to Regulation 534.4.1.1 have been amended to remove examples of equipment.

Regulation 701.1 has been amended to remove the reference to birthing pools.

A new Regulation, 710.422.2.201, has been included in order to modify requirements in Regulation group 422.2 for protected escape routes in healthcare facilities.

# BS 7671:2018+A2:2022 - Corrigendum (May 2023)

## SECTION 422

### 422 PRECAUTIONS WHERE PARTICULAR RISKS OF FIRE EXIST

#### 422.2 Protected escape routes

Cables or other electrical equipment shall not be installed in a firefighting lobby, shaft or staircase of a protected escape route unless part of:

- (i) an essential fire safety or related safety system
- (ii) general needs lighting
- (iii) socket-outlets provided for cleaning or maintenance.

**NOTE 1:** Guidance is provided in Appendix 13.

**NOTE 2:** Generally, this means cables in a firefighting lobby, shaft or staircase of a protected escape route should be limited to lighting and associated accessories, emergency lighting and fire detection and alarm systems, although cables for other safety systems may be necessary. Hospitals may have special requirements as detailed in Section 710.

# BS 7671:2018+A2:2022 - Corrigendum (May 2023)

## SECTION 443

### 443 PROTECTION AGAINST TRANSIENT OVERVOLTAGES OF ATMOSPHERIC ORIGIN OR DUE TO SWITCHING

#### 443.4.1 Transient overvoltages due to the effects of indirect lightning strokes

Protection against transient overvoltages shall be provided where the consequence caused by the overvoltage could result in:

- (i) serious injury to, or loss of, human life
- (ii) ~~failure of a safety service, as defined in Part 2 Deleted by BS 7671:2018+A2:2022, Corrigendum (May 2023)~~
- (iii) significant financial or data loss.

For all other cases, protection against transient overvoltages shall be provided unless the owner of the installation declares it is not required due to any loss or damage being tolerable and they accept the risk of damage to equipment and any consequential loss.

#### 443.6.2 Rated impulse voltages of equipment and overvoltage categories

Category IV equipment is suitable for use at, or in the proximity of, the origin of the electrical installation, for example, upstream of the main distribution board. Equipment of category IV has a very high impulse withstand capability providing the required high degree of reliability, and shall have a rated impulse voltage not less than the value specified in Table 443.2.

Category III equipment is suitable for use in the fixed installation downstream of and including the main distribution board, providing a high degree of availability, and shall have a rated impulse voltage not less than the value specified in Table 443.2.

Category II equipment is suitable for connection to the fixed installation, providing a degree of availability normally required for current-using equipment, and shall have a rated impulse voltage not less than the value specified in Table 443.2.

Category I equipment is only suitable for use in the fixed installation where SPDs are installed outside the equipment to limit transient overvoltages to the specified level, and shall have a rated impulse voltage not less than the value specified in Table 443.2. Therefore, equipment with a rated impulse voltage corresponding to overvoltage category I should, preferably, not be installed at or near the origin of the installation.

## BS 7671:2018+A2:2022 - Corrigendum (May 2023)

**TABLE 443.2 – Required rated impulse voltage of equipment ( $U_w$ )**

Nominal voltage of the installation $V^a$	Voltage line to neutral derived from nominal voltages AC or DC up to and including V	Required rated impulse voltage of equipment <sup>b</sup> kV			
		Overvoltage category IV (equipment with very high rated impulse voltage)	Overvoltage category III (equipment with high rated impulse voltage)	Overvoltage category II (equipment with normal rated impulse voltage)	Overvoltage category I (equipment with reduced rated impulse voltage)
		For example, energy meter, telecontrol systems	For example, distribution boards, switches socket-outlets	For example, domestic appliances, tools	For example, sensitive electronic equipment <del>such as alarm panels, computers and home electronics</del>
120/208	150	4	2.5	1.5	0.8
230/400 <sup>c</sup> 277/480	300	6	4	2.5	1.5
400/690	600	8	6	4	2.5
1000	1000	12	8	6	4
1500 DC	1500 DC	-	-	-	-
<p>a According to BS EN 60038.</p> <p>b This rated impulse voltage is applied between live conductors and PE.</p> <p>c For IT systems operating at 220-240 V, the 230/400 row should be used, due to the voltage to earth at the earth fault on one line.</p>					



# BS 7671:2018+A2:2022 - Corrigendum (May 2023)

## SECTION 534

### 534 DEVICES FOR PROTECTION AGAINST OVERVOLTAGE

**534.4.1.1** Where SPDs are required:

- (i) SPDs installed at the origin of the electrical installation shall be Type 1 or Type 2
- (ii) SPDs installed close to sensitive equipment to further protect against switching transients originating within the building shall be Type 2 or Type 3.

**NOTE:** Type 1 SPDs are often referred to as equipotential bonding SPDs and are fitted at the origin of the electrical installation to specifically prevent dangerous sparking which could lead to fire or electric shock hazards. In accordance with BS EN 62305-4, a lightning protection system which only employs equipotential bonding SPDs provides no effective protection against failure of sensitive electrical and electronic systems. Further SPDs (Type 2 and Type 3) are required to protect sensitive and critical equipment (for example, hospital equipment ~~and fire/security alarm systems~~) downstream of the origin of the electrical installation.

# BS 7671:2018+A2:2022 - Corrigendum (May 2023)

## SECTION 701

### LOCATIONS CONTAINING A BATH OR SHOWER

#### 701.1 Scope

The particular requirements of this section apply to the electrical installations in locations containing a fixed bath (bath tub, ~~birthing pool~~) or shower and to the surrounding zones as described in these regulations. |

This section does not apply to emergency facilities such as emergency showers used in industrial areas or laboratories.

# BS 7671:2018+A2:2022 - Corrigendum (May 2023)

## SECTION 710 MEDICAL LOCATIONS

**710.422.2.201** Within a healthcare facility, cables or other electrical equipment may be installed in a protected escape route, where:

- (i) the healthcare facility complies with Health Technical Memoranda (HTM) and healthcare fire safety guidance, and
- (ii) the particulars of the electrical installation within the protected escape route are documented as part of a fire strategy.

**NOTE:** Specific guidance on fire safety for healthcare premises can be found in relevant Health Technical Memoranda as published by the Department of Health/NHS England. There are equivalent guidance documents in other devolved administrations, e.g. Scotland (SHTM) and Wales (WHTM).