

Guidance Note 3 (BS 7671:2018+A4:2026) Tenth Edition – Errata (April 2026)

This document contains corrections to the 2026 first printing of the Tenth Edition of Guidance Note 3 (BS 7671:2018+A4:2026). These will be incorporated in the digital version and any future reprints, and are intended for immediate implementation. Where appropriate, deleted text has been ruled through and changes and additions shown in red. Sufficient existing text has been included to enable users to identify the nature and application of the change.

Page 73

In the example of the test prior to connection for insulation resistance of a three- phase 4-core power cable, starting on page 72,

'The insulation resistance readings obtained should be not less than the minimum values referred to in Table ~~2.9~~'.

should read

'The insulation resistance readings obtained should be not less than the minimum values referred to in Table 2.10'.

Page 176

In the heading to Table B3, 'Conductor temperature factor ~~F~~ for standard devices' has been amended to 'Conductor temperature factor C_r for standard devices'.